



LABELS

DC & AC Disconnect (per NEC 690.17)

"WARNING: ELECTRIC SHOCK HAZARD. DO NOT TOUCH TERMINALS, TERMINALS ON BOTH LINE AND LOAD SIDES MAY BE ENERGIZED IN OPEN POSITION."

Main Service Panel (per NEC 705.10)

"THIS ELECTRICAL SYSTEM IS ALSO SERVED BY A PHOTOVOLTAIC SYSTEM."

NOTES

All supplied equipment is U.L. Listed.

Equipment to be installed per listing or labeling and NEC Requirements.

Grounding conductors connected to each model frame and rack assembly

All solar panels are UL Listed to UL 1703 and have a Class C Fire Rating

<p>Installer:</p>	<p>3.06 DC Watt Photovoltaic Solar Array (18) Ningbo Solar Panels 170 W each (1) PV Powered 3000 W Inverter Roof Type:</p>	<p>Installation Site:</p>
-------------------	---	---------------------------